

1320 Research Park Drive
Manhattan, KS 66502
785-564-6700
www. agriculture.ks.gov



900 SW Jackson, Room 456
Topeka, KS 66612
785-296-3556

Mike Beam, Secretary

Laura Kelly, Governor

December 5, 2024

Randy Schultz
Badger Meter, Inc.
4545 W Brown Deer Road
Milwaukee, WI 53223

Dear Mr. Schultz,

I am pleased to inform you that the information included with your May 9, 2024 request, along with additional information received through several emails, for the following water flowmeter series model, has been reviewed and it has been determined that the water flowmeter model series meet the specifications of the Chief Engineer as adopted in K.A.R. 5-1-4, subject to the conditions listed below, and will be included on the List of Certified Water Flowmeters maintained in accordance with K.A.R. 5-1-12.

Badger RecordAll Disc Series Meters, M25, M35, M55, and M70, 5/8" to 1"

The meter couplings must have a hole through which a wire seal can be passed. The register must be equipped with a tamper-evident wire seal.

Placement on the list means the above-named model series, when properly installed, will be accepted to meet water flowmeter requirements imposed by the Chief Engineer.

Sincerely yours,

Earl D. Lewis, Jr., P.E.
Chief Engineer

Pc:

Topeka Field Office
Stafford Field Office
Stockton Field Office
Garden City Field Office